

APPLICATION PACKET FOR:

Water & Sewer Will Serve

Applicant Must Receive A Water & Sewer Will Serve Letter
And

An Architectural Review Approval Letter From TRI Center Prior To Obtaining Their Building Permit From Storey County.

Grading Only permits require no approvals from TRI Center.



Items required for water/sewer will serve letter review:

1	TRI Water and Sewer Service Application and Agreement.
2	_2 sets of wet stamped civil drawings.
3	_2 sets of landscape plans.
4	1 set of mechanical/plumbing plans showing all plumbing fixtures.
5	Plan check fees \$500 dollars. Made payable to TRI Water and Sewer Company.
6	Inspection deposit \$1000 dollars. Made payable to TRI Water and Sewer Company.
7	TRI Water Use Calculation Sheet completed by registered engineer.
8	Sewer Pretreatment Checklist.
9	Parcel Map
Items	required after review & prior to release of water/sewer will serve:
10	Additional water rights payment receipt (if required).
11	Sewer connection fees as calculated on TRI Water Use Calculation Sheet. Made payable to TRI GID.
12	Water connection fee as calculated on TRI Water Use Calculation Sheet. Made payable to TRI GID.

Submit completed applications to:

Vincent Griffith Tahoe-Reno Industrial Center Water & Sewer Co. c/o Reno Engineering Corporation 8725 Technology Drive Suite C Reno Nevada 89521

Phone: (775) 852-5700 Fax: (775) 852-5707 Vince@recnv.com

TRI GENERAL IMPROVEMENT DISTRICT

8725 Technology Drive "C" Reno Nevada 89521

Water And Sewer Service Application And Agreement

TRI General Improvement District is hereby requested by the undersigned Applicant and Owner to furnish water and sewer service. In consideration for such service, Applicant and Owner represent and agree as follows; (1) All services and charges are governed by the Rules, Regulations And Rates Of The TRI General Improvement District ("Rules") and may be modified from time to time, and Applicant and Owner agree to be bound by and comply with the Rules, which are incorporated therein as though fully set forth, and any other rules or policies promulgated by the District. A copy of the Rules is available upon request for inspection at the District operating office. (2) The District is hereby granted access to the service premises for service purposes. (3) All statements of the Applicant and Owner in the application are sworn to be true, and made under penalty of perjury and are subject to appropriate civil and criminal redress, including service termination. (4) The application, when accepted by the District, constitutes a binding contract between the Applicant and Owner and the District.

Name of Applicant

* *		
Name of Business:	Assessor' s Parcel No.:	
Service Address:		
Mailing Address:	Phone Number:	
Name of Owner:	Phone Number:	
Owner's Address:		
Application Date:		
** Indicate who to bill above		
Type of Service Requested:	Domestic Water:	
	Private Fire Protection:	
	Sewer:	
Signature of Applicant	Signature of Owner	
Title:	Title:	
FOR (OFFICE USE ONLY	
District Acceptance Date:	Service Area:	
Accepted by District:(Signature)	Account Number:	
Title:		
Amount of Deposit:	Cash or Check No	

TRI GENERAL IMPROVEMENT DISTRICT Sewer Pretreatment Checklist

Please review the following form. The Maximum Concentrations correspond to the the highest level of constituent that may be discharged into the TRI sewer at any point of connection without an industrial discharge permit. Please sign at bottom of this sheet when finished. If you expect any exceedances of the following contact the Water and Sewer Company for an industrial discharge permit.

Constituent	Maximum Concentration	Concentration if Above Maximum
Arsenic	0.01 mg/L	
Barium	2 mg/L	
BOD ₅	240 mg/L	
Boron	1 mg/L	
Cadmium	0.01 mg/L	
Chloride	250 mg/L	
Chromium	0.1 mg/L	
Copper	1.0 mg/L	
Cyanide	0.20 mg/L	
Fluoride	4.0 mg/L	
Iron	25.0 mg/L	
Lead	0.3 mg/L	
Manganese	0.7 mg/L	
Mercury	0.01 mg/L	
Nickel	1.80 mg/L	
PH	6 – 9	
Phenol	.005 mg/L	
Phosphorus	8.0 mg/L	
Selenium	0.05 mg/L	
Silver	0.01 mg/L	
Sulfate	240 mg/L	
TDS	500 mg/L	
Temperature	100 F	
TKN	40 mg/L	
Total Nitrogen	20 mg/L	
TPE	1.0 mg/L	
TSS	240 mg/L	
Zinc	1.0 mg/L	

Items not listed are assumed to be below drinking water standards.

I have reviewed the above maximum concentration levels and hereby state that the discharge for my development into the TRI sewer contains no constituents in excess of the maximum concentration levels stated above. If any item exceeds the concentrations noted I understand that I will need a Indsutrial Discharge Permit Prior to dicharging.

Name:	Title	_Date:
Project Name:	Signed:	